

Consumer Notice of Lead & Copper Results in Drinking Water

Water Supply Name: City of Flint
 County: Genesee WSSN: 2310
 Sample Location: 212 Browning Date Sampled: 2/18/2015

Thank you for participating in the lead and copper monitoring of drinking water. The levels of lead and copper found at your location are in the table below.

Key to Table	Contaminant	AL	MCLG	Your Result
Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow. Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water which there is no known or expected risk to health. MCLG's allow for a margin of safety. ppb: parts per billion or micrograms per liter.	Lead (ppb)	15	0	104
	Copper (ppb)	1300	1300	Not Detected

Lead can cause serious health problem if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys, and it can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Scientists have linked the effects on the brain with lower IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults. Lead is stored in the bones, and can be released later in life. During pregnancy, the child receives lead from the mother's bones, which may affect brain development.

To reduce exposure to lead in drinking water:

- *Run your water to flush out lead.* Run the water until it becomes cold.
- *Use cold water for cooking and preparing baby formula.* Do not cook with or drink water from the hot tap; lead dissolves more easily in hot water.
- *Do not boil water to remove lead.* Boiling water will not reduce lead levels.
- *Look for an alternative sources or treatment of water.* If your lead result is above 15 ppb, you may want to consider purchasing bottled water or a water filter. Read the package to be sure the filter is approved to reduce lead or contact NSF International at 800-NSF-8010, or www.nsf.org for information on performance standards for water filters.
- *Identify if your plumbing fixtures contain lead.* New faucets, fittings, and valves, may contain up to 8 percent lead including those advertised as "lead-free" and may contribute lead to drinking water. Consumers should be aware of this when choosing fixtures and take appropriate precautions.

Although the primary sources of lead exposure for most children are deteriorating lead-based paint, lead-contaminated dust, and lead contaminated soil, the U.S. EPA estimates that 10 to 20 percent of human exposure to lead may come from drinking water.

For more information, contact us at: *City of Flint Water Plant (810)787-6537.*

For more information on reducing lead exposure around your home and the health effects of lead, visit the U.S. EPA's Web site at www.epa.gov/lead, call the National Lead Information Center at 800-424-LEAD, or contact your health care provider.



MICHIGAN DEPARTMENT OF ENVIRONMENTAL QUALITY
 DRINKING WATER LABORATORY

USEPA Region V Drinking Water Cert. No. M100003
 P.O. Box 30270
 Lansing, MI 48909
 TEL: (517) 335-8184
 FAX: (517) 335-8582

Sample Number
 LF54945

Official Laboratory Report

Report To: MIKE GLASGOW
 4500 N DORT HWY
 FLINT MI 48606

System Name/Owner:	CITY OF FLINT	WSSN/Pool ID:	2310
Collection Address:	212 BROWNING AVE, FLINT	Source:	TYPE 1
Collected By:	LEANNE WALTERS	Site Code:	
Township/Well#/Section:	//	Collector:	Private Citizen
County:	Genesee	Date Collected:	02/18/2015 07:15
Sample Point:	KITCHEN	Date Received:	02/19/2015 11:13
Water System:	Treated Public Distribution System	Purpose:	Routine Monitoring

TESTING INFORMATION			REGULATORY INFORMATION			
Analyte Name	Result (mg/L)	Date Tested	RL (mg/L)	MCL/AL (mg/L)	Method	CAS #
Copper	Not detected	02/20/2015	0.05	1.3	EPA 200.8	7440-50-8
Lead	0.104	02/20/2015	0.001	0.015	EPA 200.8	7439-92-1

The analyses performed by the MDEQ Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below:

Genesee County Health Dept.
 630 South Saginaw
 Flint, MI 48602-1540
 810 257-3603

CAS#: Chemical Abstract Service Registry Number	mg/L : milligrams / Liter (ppm)	Laboratory Contacts
MCL : Maximum Contaminant Level	ppm : parts per million	Drinking Water Unit Mgr: Julie Piaper
AL : Action Level	MPN : Most Probable Number	Systems Mgmt. Unit Mgr: George Krisztián
RL : Reporting Limit	CFU : Colony Forming Unit	